



NOTE A: CHANGE CAT F17 TO 15A  
 NOTE B: JUMPER TERMINAL 142 TO N FOR NEUTRAL  
 REMOVE WIRE FROM L2 TO F18  
 NOTE C: CONNECT GEN SPACE HEATER FOR 120V.  
 NOTE D: MOVE CAT BATTERY CHARGER NEG WIRE TO  
 TO BATTERY SIDE OF ISOLATION SWITCH  
 - - - - - EXISTING CAT WIRING

CHANGE NOTICE 1 NO		<b>ALTORFER</b> 6315 W. FAUBER RD. BARTONVILLE, IL 61607 PHONE (309) 697-1234 FAX (309) 282-7546		<b>ALTORFER POWER SYSTEMS</b> PROJECT REFERENCE APS800A C27 POWER MODULE	
		THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF ALTORFER, INC. WITHOUT THE WRITTEN PERMISSION OF ALTORFER, INC., ANY COPYING OR OTHER USE EXCEPT THAT FOR WHICH IT WAS INTENDED IS PROHIBITED		SCALE/SHEET SIZE 1=1/C DATE 8/10/06	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED TOLERANCES: .XX ± 0.100 .XXX ± 0.060 .XXXX ± 0.005 ANGULAR ± 1°		FILE DF\80E		DRAWN BY D. RICHARDSON	
THIRD ANGLE PROJECTION		SHEET 1 OF 1		WORK ORDER NUMBER	
TITLE SHORE POWER GROUP DIAGRAM - WIRING		DRAWING NUMBER 80E172		QUOTE NUMBER	