





ITEM	QTY.	PART NO. & DESCRIPTION
1	2	86C151-ROOF ACCESS PLATE
2	20	343-4072-M6X1X25MM FL HD BOLT
3	20	317-5700-NEOPREME WASHER
4	11 FT.	STICKERTITE
5	1	BSP1024-LSS-SOLAR PANEL
6	4	11508896-S.S. BOLT (M5x0.78)
7	4	90133A032-WASHER - RUBBER
8	1	9X-0352-2 PIN RECEPTACLE ASSEMBLY
9	1	155-2270-2 PIN CONNECTOR PLUG
10	2	8T-8730-PIN
11	1	136-7226-O-RING SEAL
12	1	HSTT75-Y-HEAT SHRINK BLACK 3/4'
13	3	5P-9085-CLIP
14	62	198-4776-WASHER-HARD
15	62	8T-4908-BOLT-M8X1.25
16	8	316-9831-HOLDER-LADDER
17	32	342-9922-BOLT-FL HD M8X1.25
18	2	81C512-INTAKE LOUVER AS.
19	1	88A170-MTG. H/W GROUP-STREETSIDE-INTAKE DOOR
20	1	88A171-MTG. H/W GROUP-CURBSIDE-INTAKE DOOR
21	1	88A172-MTG. H/W GROUP-PERSONNEL DOOR
22	1	311-9290-PLATE ASSEMBLY-REMOTE FUEL FILL & DRAIN
23	4	6V-7357 - M6X1 BOLT-ZINC PLATED
24	2	DH-6W-FS-HOLDER/LATCH KIT
25	16	0126271-1/8" PDP RIVET S/S
26	3	0221241-SIKAFLEX SEALANT-WHITE
27	3	88C221 - DRIP EDGE
28	2	88C222 - DRIP EDGE
29	25	12544519-1/4"-14THDX1.00' LG. THREAD CUTTING SCREW



NOTE A: INSTALL STICKERTITE ON BACK SIDE OF PLATE.  
 NOTE B: DRILL PILOT HOLES FOR 1/4"-14THD. INSTALL WHITE CAULK CONTINUOUSLY ALONG TOP SEAM OF DRIP EDGE.  
 NOTE C: ADD SILICONE TO (9X-0352) 2 PIN RECEPTACLE ASSEMBLY AND CONTAINER UPON INSTALLATION.  
 NOTE D: BLACK WIRE TO PIN 2 & WHITE WIRE TO PIN 1.  
 NOTE E: INSTALL W/ BLUE LOCKTITE AND TORQUE TO 6 Nm.

		<b>ALTORFER POWER SYSTEMS</b> 6315 W. FAUBER RD. PHONE (309) 697-1234 BARTONVILLE, IL 61807 FAX (309) 262-7546	
		THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF ALTORFER, INC. WITHOUT THE WRITTEN PERMISSION OF ALTORFER, INC., ANY COPYING OR OTHER USE EXCEPT THAT FOR WHICH IT WAS INTENDED IS PROHIBITED.	
CHANGE NOTICE ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED TOLERANCES: XX ± 0.100 XXX ± 0.060 XXXX ± 0.005 ANGULAR ± 1°	FILE DF/81A	PROJECT REFERENCE APS1000A	QUOTE NUMBER -
	SCALE/SHEET SIZE 1=25/D	DRAWN BY JAM	WORK ORDER NUMBER -
	SHEET 1 OF 1	DATE 01-14-15	DRAWING NUMBER 81A516-00
	TITLE CONTAINER ACCESS MOUNTING GROUP		