



ITEM	QTY.	PART NO. & DESCRIPTION
1	2	308-4542 - ISOLATOR-MOUNTING
2	2	8T-5439 - WASHER
3	2	8T-6430 - BOLT-M20X2.5
4	8	8T-4179 - BOLT-M12X1.75
5	8	5P-1076 - WASHER-HARD
6	6	112-3926 - BOLT-HEX HD. M20X2.5
7	6	90685 - LOCKNUT-HEX M20X2.5
8	24	8T-4123 - WASHER-HARD
9	1	3810.059.0000-AKG RADIATOR W/ 61" FAN SHRD.
10	1	336-7174-BRACE AS.-LH
11	1	336-7173-BRACE AS.-RH
12	4	8T-4132-NUT-HEX HD. M16X2.0
13	8	3E-9411-WASHER-HARD
14	4	7X-2554-BOLT-M16X2.0
15	4	7X-0550-WASHER-HARD
16	4	8T-4184-BOLT-M12X1.75
17	1	371-0872-SENSOR GP-LEVEL (COOLANT)
18	1	338-8901-FAN GUARD GROUP
19	1	356-4971-FAN AS.-RADIATOR
20	6	8T-4223-WASHER-HARD
21	6	8T-8919-BOLT-1/2"-13THD
22	1	339-6197-02-LINES GP-COOLANT



- NOTE A: AKG RADIATOR PURCHASED FROM QUOTE# ASJ0703141459
- NOTE B: USE THIS 1/4" NPT PORT TO INSTALL COOLANT LEVEL SENSOR GP. ROUTE HARNESS TO WATER PUMP HARNESS TERM. PLUG.
- NOTE C: REF. 338-8901-03 FOR FAN GUARD KIT INSTALLATION DETAILS. CONNECT SENSOR HARNESS TO ENGINE HARNESS.

DATE BY		<b>ALTORFER</b>		<b>ALTORFER POWER SYSTEMS</b>	
		6315 W. FAUBER RD.		PHONE (309) 697-1234	
		BARTONVILLE, IL 61607		FAX (309) 282-7546	
THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION OF ALTORFER, INC. WITHOUT THE WRITTEN PERMISSION OF ALTORFER, INC., ANY COPYING OR OTHER USE EXCEPT THAT FOR WHICH IT WAS INTENDED IS PROHIBITED					
CHANGE NOTICE	ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED	FILE	PROJECT REFERENCE		
		DF\81A	APS1000A-RM		
	TOLERANCES: X.X ± 0.100 X.XX ± 0.060 X.XXX ± 0.005	THIRD ANGLE PROJECTION	SCALE/SHEET SIZE	DRAWN BY	QUOTE NUMBER
	ANGULAR ± 1°		1=10/D	JAM	-
TITLE		SHEET	DATE	WORK ORDER NUMBER	
		1 OF 1	12-13-18	-	
NO.	RADIATOR MOUNTING GROUP				DRAWING NUMBER
					81A607